

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1062:119 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Detection Systems, 130 Perinton Parkway, Fairport NY 14450
Contact: Frank Mioduszewski (585) 223-4060 FAX (585) 421-4263

DESIGN: Model DS9471 and DS9471C digital alarm communicator transmitter (DACT). Stand-alone or slave applications. Intended for off-premises monitoring of an existing fire alarm control panel. Unit in stand-alone mode does not comply with NFPA 72 for notification appliance circuits. Refer to listee's data sheet for detailed product description and operational considerations. Basic components:

D126	Battery
D161/D162	Phone Cord (2)
D1220	Transformer
D8004	Transformer Enclosure

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as digital alarm communicator transmitter control unit when used with separately listed compatible fire alarm control units, initiating and indicating signal devices. Not suitable for use as stand-alone fire alarm control panel. Refer to listee's Installation Instruction Manual for details.

NOTE: Non-fire functions were not examined.

XLF: 7165-0801:108

*Rev. 05-05-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**